SLIDE-OUT CHASSIS BASE NOMENCLATURE

B 03 2P – 30 – S L 20 – M### M### – XXX

B — BASE RFC MODULE

03 — SIZE NOMINAL
- 03 – 300 CFM
- 04 – 400 CFM
- 06 – 600 CFM
- 08 – 800 CFM
- 10 – 1000 CFM
- 12 – 1200 CFM

2P — APPLICATION
- CO - COOLING ONLY
- HO - HEATING ONLY
- 2P - HEATING & COOLING
- 4P - 2 PIPE COOLING & 2 PIPE (1 ROW) HEATING
- ET - TOTAL ELECTRIC HEATING
- EA - AUXILIARY ELECTRIC HEATING

30 — COIL PACKAGE CONFIGURATION
- 20 - 2 ROW COOLING & NO HEATING
- 30 - 3 ROW COOLING & NO HEATING
- 31 - 3 ROW COOLING & 1 ROW HEATING
- 32 - 3 ROW COOLING & 2 ROW HEATING
- 40 - 4 ROW COOLING & NO HEATING
- 41 - 4 ROW COOLING & 1 ROW HEATING
- 42 - 4 ROW COOLING & 2 ROW HEATING
- 50 - 5 ROW COOLING & NO HEATING
- 51 - 5 ROW COOLING & 1 ROW HEATING
- SP – 4 ROW SPLIT “50/50” COIL

S — VALVE ACTUATOR OPERATION
- S - Two Position
- F - Floating Point
- P - Proportional
- X - None

L — VALVE ACTUATOR VOLTAGE
- L - 24 VAC
- A - 115 VAC
- B - 208-230 VAC
- D - 265 VAC
- X - N/A

20 — VALVE BODY CONFIGURATION
- 20 - 2P: Two Way
- 30 - 2P: Three Way
- 22 - 4P: Cold: 2 Way; Hot: 2 Way
- 32 - 4P: Cold: 3 Way; Hot: 2 Way
- 23 - 4P: Cold: 2 Way; Hot: 3 Way
- 33 - 4P: Cold: 3 Way; Hot: 3 Way
- XX - None

M### M### — FLOW CONTROL 2P (4P as applicable)
- X000 - None
- M### - Manual Balancing
- A### - Automatic Balancing
- P### – Auto w PT ports
  - *### - GPM Flow Rate

XXX — ADDITIONAL OPTIONS

STR - Strainer
STBD - Strainer with Blowdown